



February 20, 2026

Associate Director, Water Enforcement
U.S. Environmental Protection Agency
Region VI
1201 Elm Street, Suite 500
Mail Code ECADW
Dallas, Texas 75270-2102

Via E-mail: Smalley.bryant@epa.gov

Re: City of Houston Wastewater Consent Decree
Civil Action No. 4:18-cv-03368
Monthly SSO Report – January 2026

Dear Mr. Smalley:

The City of Houston's monthly SSO summary report for January 2026 and corresponding SSO map are attached and provided in compliance with the requirements of Paragraph 61 of the City of Houston Wastewater Consent Decree.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

DocuSigned by:
A handwritten signature in blue ink, appearing to read "Phillip Goodwin".
08B3519C2897428

Phillip Goodwin

Regulatory Compliance Director
Houston Public Works, City of Houston

Enc. January 2026 Monthly SSO Report; SSO Map for January 2026
cc via email: Thomas Carroll, DOJ (Thomas.Carroll@usdoj.gov)
James Zimny, EPA (Zimny.james@epa.gov)
Alan Vaughn, EPA (vaughn.alan@epa.gov)
Brittany Wright, Texas AG's Office (Brittany.Wright@oag.texas.gov)
James Sallans, TCEQ (james.sallans@tceq.texas.gov)
Kristen Schlemmer, BCWK (kristen@bayoucitywaterkeeper.org)



City of Houston - Houston Public Works
 Monthly SSO Report
 January 2026

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
65860	WQ0010495090	1011 10TH ST	Storm Sewer (not contained)	Yes	505	Manhole	Collection system temporary blockage	1/2/2026	8:58:00	1/2/2026	10:39:00	5	Cleared Main Line; Cleaned and Disinfected
65867	WQ0010495002	7373 ARDMORE ST	Storm Sewer (not contained)	Yes	14065	Manhole	Grease Blockage	1/2/2026	12:04:00	1/4/2026	11:11:00	5	Cleared Main Line; Cleaned and Disinfected
65868	WQ0010495075	10418 SOUTHPORT DR	Storm Sewer (not contained)	Yes	3304	Gravity Main	Grease Blockage	1/2/2026	11:26:00	1/2/2026	18:19:00	8	Cleaned and Disinfected; Cleared Main Line
65869	WQ0010495002	2351 EAGLE ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural failure	1/2/2026	14:01:00	1/2/2026	14:02:00	0	Cleared City Clean Out; Cleaned and Disinfected
65870	WQ0010495002	4108 EMANCIPATION AVE	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural blockage	1/2/2026	14:17:00	1/2/2026	14:18:00	0	Cleared Service Lateral; Cleaned and Disinfected
65871	WQ0010495116	12630 ASHFORD POINT DR	Storm Sewer (not contained)	Yes	25	Private Cleanout	Grease Blockage	1/2/2026	15:45:00	1/2/2026	16:10:00	1	Cleared City Clean Out; Cleaned and Disinfected
65872	WQ0010495090	12630 ASHFORD POINT DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/2/2026	15:10:00	1/2/2026	15:11:00	0	Cleared City Clean Out; Cleaned and Disinfected
65875	WQ0010495003	10830 FAIRLAND DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/2/2026	16:49:00	1/2/2026	16:50:00	0	Cleaned and Disinfected; Cleared Main Line
65878	WQ0010495002	6652 MERRY LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/3/2026	10:54:00	1/3/2026	10:55:00	0	Cleaned and Disinfected
65881	WQ0010495075	11006 SAGERIVER DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/3/2026	14:00:00	1/3/2026	14:01:00	0	Set Bypass Pump; Cleaned and Disinfected
65885	WQ0010495090	6009 NORDLING RD	Storm Sewer (not contained)	Yes	0	City Cleanout	Grease Blockage	1/4/2026	8:30:00	1/4/2026	8:31:00	0	Cleaned and Disinfected; Cleared City Clean Out
65887	WQ0010495077	936 HALSEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/4/2026	9:30:00	1/4/2026	9:31:00	0	Cleared City Clean Out; Cleaned and Disinfected
65889	WQ0010495009	5238 BUNGALOW LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/4/2026	9:40:00	1/4/2026	9:41:00	0	Cleaned and Disinfected
65893	WQ0010495003	2712 SOUTHWEST FWY	Storm Sewer (not contained)	Yes	910	Manhole	Grease Blockage	1/5/2026	10:01:00	1/5/2026	13:03:00	5	Cleared Main Line; Cleaned and Disinfected
65899	WQ0010495116	12850 WHITTINGTON DR	Storm Sewer (not contained)	Yes	32	City Cleanout	Collection system structural failure	1/5/2026	11:48:00	1/5/2026	12:20:00	1	Set Bypass Pump; Cleaned and Disinfected
65900	WQ0010495002	7208 OAK HILL DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/5/2026	11:31:00	1/5/2026	11:32:00	0	Cleaned and Disinfected
65901	WQ0010495079	9223 FUQUA BREEZE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/5/2026	11:50:00	1/5/2026	11:51:00	0	Cleaned and Disinfected
65903	WQ0010495030	3125 CRESTDALE DR	Storm Sewer (not contained)	Yes	520	Manhole	Grease Blockage	1/5/2026	12:40:00	1/5/2026	17:00:00	2	Cleared Main Line; Cleaned and Disinfected
65909	WQ0010495016	8210 CRESTVIEW DR	Bayou/surface water/drainage ditch	Yes	116	Service Lateral	Grease Blockage	1/5/2026	14:07:00	1/5/2026	16:03:00	1	Cleared Main Line; Cleaned and Disinfected
65913	WQ0010495090	3635 PERSIMMON ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Collection system structural failure	1/5/2026	14:13:00	1/5/2026	14:14:00	0	Cleaned and Disinfected
65915	WQ0010495090	2321 MARONEAL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/5/2026	17:07:00	1/5/2026	17:08:00	0	Cleaned and Disinfected
65916	WQ0010495003	3514 SHEPHERD DR	Storm Sewer (not contained)	Yes	0	Private Sample Well	Grease Blockage	1/6/2026	8:23:00	1/6/2026	8:24:00	0	Cleared Main Line; Cleaned and Disinfected
65917	WQ0010495090	1011 10TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	247	Manhole	Grease Blockage	1/6/2026	9:14:00	1/6/2026	13:21:00	1	Cleaned and Disinfected; Cleared Main Line
65919	WQ0010495090	1613 WOODHEAD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/6/2026	10:53:00	1/6/2026	10:54:00	0	Cleaned and Disinfected
65928	WQ0010495090	4400 18TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/6/2026	12:22:00	1/6/2026	12:23:00	0	Cleared Main Line; Cleaned and Disinfected
65929	WQ0010495002	5122 WINNETKA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/6/2026	13:54:00	1/6/2026	13:55:00	0	Cleaned and Disinfected
65930	WQ0010495090	310 ROBERT LEE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/6/2026	14:20:00	1/6/2026	14:21:00	0	Cleared City Clean Out; Cleaned and Disinfected
65931	WQ0010495002	2820 DALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/6/2026	15:50:00	1/6/2026	15:51:00	0	Cleaned and Disinfected
65938	WQ0010495002	7111 EPPES ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/7/2026	10:03:00	1/7/2026	10:04:00	0	Cleared City Clean Out; Cleaned and Disinfected
65941	WQ0010495037	3917 GRAMERCY ST	Storm Sewer (not contained)	Yes	63	Service Lateral	Collection system structural failure	1/7/2026	11:17:00	1/7/2026	15:28:00	0	Set Bypass Pump; Cleaned and Disinfected
65943	WQ0010495122	5922 BENDER RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/7/2026	12:38:00	1/7/2026	12:39:00	0	Cleaned and Disinfected; Cleared Service Lateral
65946	WQ0010495109	1250 ELDRIDGE PKWY	Storm Sewer (not contained)	Yes	0	Private Cleanout	Grease Blockage	1/7/2026	14:21:00	1/7/2026	14:22:00	0	Cleared City Clean Out; Cleaned and Disinfected
65951	WQ0010495037	6009 BEVERLY HILL ST	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	387	City Cleanout	Rags/Wipes	1/7/2026	15:51:00	1/7/2026	18:00:00	3	Cleared City Clean Out; Cleaned and Disinfected
65952	WQ0010495110	5067 RIDGE CREEK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/8/2026	9:05:00	1/8/2026	9:06:00	0	Cleaned and Disinfected
65953	WQ0010495003	4447 MOUNT VERNON ST	Storm Sewer (not contained)	Yes	0	Service Lateral	Grease Blockage	1/8/2026	10:05:00	1/8/2026	10:06:00	0	Cleared Main Line; Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



City of Houston - Houston Public Works
 Monthly SSO Report
 January 2026

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
65961	WQ0010495003	4122 PURDUE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/8/2026	13:44:00	1/8/2026	13:45:00	0	Cleaned and Disinfected; Cleared City Clean Out
65963	WQ0010495003	4206 HOWCHER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/8/2026	15:20:00	1/8/2026	15:21:00	0	Cleaned and Disinfected; Cleared City Clean Out
65969	WQ0010495090	1207 PRAIRIE ST	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	1/9/2026	10:15:00	1/9/2026	10:16:00	0	Cleared City Clean Out; Cleaned and Disinfected
65972	WQ0010495109	12600 BRIAR FOREST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	1/9/2026	12:44:00	1/9/2026	12:45:00	0	Cleaned and Disinfected; Cleared Main Line
65974	WQ0010495002	5802 FLAMINGO DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/9/2026	13:09:00	1/9/2026	13:10:00	0	Cleared City Clean Out; Cleaned and Disinfected
65976	WQ0010495109	12520 WESTHEIMER RD	Storm Sewer (not contained)	Yes	861	Manhole	Grease Blockage	1/9/2026	15:22:00	1/9/2026	18:26:00	5	Cleaned and Disinfected; Cleared Main Line
65977	WQ0010495101	215 COUNTY FAIR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/9/2026	15:00:00	1/9/2026	15:01:00	0	Cleared Main Line; Cleaned and Disinfected
65978	WQ0010495090	5302 VIKING DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/9/2026	16:29:00	1/9/2026	16:30:00	0	Set Bypass Pump; Cleaned and Disinfected
65980	WQ0010495016	9129 LAKE FOREST BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/9/2026	15:40:00	1/9/2026	15:41:00	0	Cleared City Clean Out; Cleaned and Disinfected
65987	WQ0010495002	1039 THERESA ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	1/10/2026	12:43:00	1/10/2026	12:44:00	0	Cleared City Clean Out; Cleaned and Disinfected
65989	WQ0010495146	2031 LAKE VILLAGE DR	Storm Sewer (not contained)	Yes	4690	Force Main	Collection system structural failure	1/10/2026	12:10:00	1/11/2026	11:56:00	3	Cleaned and Disinfected
66002	WQ0010495009	4141 BARBERRY DR	Storm Sewer (not contained)	Yes	476	Manhole	Grease Blockage	1/12/2026	10:14:00	1/12/2026	14:12:00	2	Cleaned and Disinfected; Cleared Main Line
66007	WQ0010495090	120 TIDWELL RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/12/2026	11:30:00	1/12/2026	11:31:00	0	Cleared Service Lateral; Cleaned and Disinfected
66009	WQ0010495090	3026 BERRY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/12/2026	12:48:00	1/12/2026	12:49:00	0	Cleared City Clean Out; Cleaned and Disinfected
66010	WQ0010495090	3902 WIPPRECHT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/12/2026	13:05:00	1/12/2026	13:06:00	0	Cleared City Clean Out; Cleaned and Disinfected
66017	WQ0010495090	8718 CLARINGTON ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Collection system structural failure	1/12/2026	15:49:00	1/12/2026	15:50:00	0	Cleared Service Lateral
66020	WQ0010495050	666 GLOBE ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	1/13/2026	8:20:00	1/13/2026	8:21:00	0	Cleaned and Disinfected; Cleared Main Line
66022	WQ0010495002	6243 SOUTHBROOK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/13/2026	9:54:00	1/13/2026	9:55:00	0	Cleaned and Disinfected; Cleared Main Line
66025	WQ0010495119	11500 KEEGANS RIDGE RD	Storm Sewer (not contained)	Yes	224	Service Lateral	Grease Blockage	1/13/2026	10:07:00	1/13/2026	13:51:00	1	Cleaned and Disinfected; Cleared Service Lateral
66026	WQ0010495090	7704 AVENUE J	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/13/2026	11:24:00	1/13/2026	11:25:00	0	Cleared City Clean Out; Cleaned and Disinfected
66028	WQ0010495090	1203 CAPLIN ST	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	1/13/2026	12:24:00	1/13/2026	12:25:00	0	Cleaned and Disinfected; Cleared Service Lateral
66032	WQ0010495002	6811 BELLFORT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural blockage	1/13/2026	15:37:00	1/13/2026	15:38:00	0	Cleared City Clean Out; Cleaned and Disinfected
66035	WQ0010495090	2015 PASKET LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/13/2026	16:41:00	1/13/2026	16:42:00	0	Cleaned and Disinfected
66037	WQ0010495037	5545 SOUTHWEST FWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/14/2026	9:15:00	1/14/2026	9:16:00	0	
66039	WQ0010495090	6018 HAMMAN ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Grease Blockage	1/14/2026	5:00:00	1/14/2026	5:01:00	0	Cleaned and Disinfected; Cleared Main Line
66042	WQ0010495016	9129 LAKE FOREST BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/14/2026	10:21:00	1/14/2026	10:22:00	0	Cleared City Clean Out; Cleaned and Disinfected
66043	WQ0010495090	515 MELBOURNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/14/2026	9:59:00	1/14/2026	10:00:00	0	Cleared City Clean Out; Cleaned and Disinfected
66044	WQ0010495023	6709 MARIOSA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	1/14/2026	10:43:00	1/14/2026	10:44:00	0	Cleared City Clean Out; Cleaned and Disinfected
66046	WQ0010495090	111 INLANE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural blockage	1/14/2026	12:20:00	1/14/2026	12:21:00	0	Set Bypass Pump
66048	WQ0010495090	1720 TERRY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/14/2026	13:39:00	1/14/2026	13:40:00	0	Cleared Main Line; Cleaned and Disinfected
66052	WQ0010495090	5050 YALE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	70	Private Cleanout	Grease Blockage	1/14/2026	15:15:00	1/14/2026	16:25:00	1	Cleaned and Disinfected; Cleared Main Line



City of Houston - Houston Public Works
 Monthly SSO Report
 January 2026

SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
66054	WQ0010495090	146 ECHO GLEN DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/14/2026	15:30:00	1/14/2026	15:31:00	0	Post Warning Signs
66057	WQ0010495090	7964 AMELIA RD	Storm Sewer (not contained)	Yes	965	Private Cleanout	Grease Blockage	1/14/2026	17:51:00	1/14/2026	21:04:00	5	Cleaned and Disinfected; Cleared Main Line
66058	WQ0010495090	1201 CLAY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/14/2026	19:24:00	1/14/2026	19:25:00	0	Cleared City Clean Out; Cleaned and Disinfected
66059	WQ0010495146	1927 THOUSAND PINES DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	764	Manhole	Grease Blockage	1/14/2026	16:53:00	1/14/2026	23:15:00	2	Cleaned and Disinfected; Cleared Main Line
66060	WQ0010495003	12827 SEGREST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/15/2026	8:06:00	1/15/2026	8:07:00	0	Cleaned and Disinfected; Cleared City Clean Out
66062	WQ0010495075	10702 SAGEDOWNE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/15/2026	9:25:00	1/15/2026	9:26:00	0	Cleaned and Disinfected; Cleared City Clean Out
66068	WQ0010495090	5519 CAPLIN ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	1/15/2026	10:49:00	1/15/2026	10:50:00	0	Cleared Main Line; Cleaned and Disinfected
66072	WQ0010495076	8215 FAWNDALE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Grease Blockage	1/15/2026	11:52:00	1/15/2026	11:53:00	0	Cleared Main Line; Cleaned and Disinfected
66080	WQ0010495090	1006 PANAMA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/15/2026	16:20:00	1/15/2026	16:21:00	0	Cleared Service Lateral; Cleaned and Disinfected
66084	WQ0010495146	1918 LAKE VILLAGE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Pump/Lift Station Electrical Failure	1/14/2026	16:53:00	1/14/2026	16:54:00	0	Cleaned and Disinfected; Set Bypass Pump
66085	WQ0010495090	809 BERRY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/16/2026	9:00:00	1/16/2026	9:01:00	0	Cleared Main Line; Cleaned and Disinfected
66087	WQ0010495090	7604 DE PRIEST ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/16/2026	10:21:00	1/16/2026	10:22:00	0	Cleaned and Disinfected; Cleared City Clean Out
66088	WQ0010495076	5421 GESSNER RD	Storm Sewer (not contained)	Yes	295	Manhole	Grease Blockage	1/16/2026	10:35:00	1/16/2026	15:30:00	1	Cleared Main Line; Cleaned and Disinfected
66090	WQ0010495110	5069 RIDGE CREEK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/16/2026	10:30:00	1/16/2026	10:31:00	0	Cleaned and Disinfected
66091	WQ0010495009	4925 CARMEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/16/2026	10:20:00	1/16/2026	10:21:00	0	Cleaned and Disinfected; Cleared City Clean Out
66094	WQ0010495110	5067 RIDGE CREEK DR	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	1/16/2026	11:22:00	1/16/2026	11:23:00	0	Cleaned and Disinfected; Set Bypass Pump
66097	WQ0010495090	1026 DOLLY WRIGHT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/16/2026	14:26:00	1/16/2026	14:27:00	0	Cleaned and Disinfected
66098	WQ0010495016	7826 HOMEWOOD LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/16/2026	14:35:00	1/16/2026	14:36:00	0	Cleaned and Disinfected
66104	WQ0010495016	9214 ARVIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	1/17/2026	13:12:00	1/17/2026	13:13:00	0	Set Bypass Pump
66108	WQ0010495109	12400 WESTHEIMER RD	Storm Sewer (not contained)	Yes	268	Manhole	Grease Blockage	1/17/2026	15:47:00	1/17/2026	18:01:00	2	Cleaned and Disinfected; Cleared Main Line
66110	WQ0010495076	4108 CLARBLAK LN	Storm Sewer (not contained)	Yes	0	Private Cleanout	Grease Blockage	1/18/2026	10:57:00	1/18/2026	10:58:00	0	Cleared Main Line; Cleaned and Disinfected
66112	WQ0010495090	169 WITCHER LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/18/2026	12:19:00	1/18/2026	12:20:00	0	Cleaned and Disinfected; Cleared City Clean Out
66113	WQ0010495076	8709 BLANKENSHIP DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/18/2026	12:00:00	1/18/2026	12:01:00	0	Cleared Main Line; Cleaned and Disinfected
66115	WQ0010495076	1219 MANSFIELD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/19/2026	9:11:00	1/19/2026	9:12:00	0	Set Bypass Pump; Cleaned and Disinfected
66118	WQ0010495002	5417 SOUTHLEA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/19/2026	11:18:00	1/19/2026	11:19:00	0	Cleared City Clean Out; Cleaned and Disinfected
66120	WQ0010495110	5003 RIDGE CREEK DR	Storm Sewer (not contained)	Yes	1327	Private Cleanout	Collection system structural failure	1/19/2026	11:31:00	1/20/2026	9:38:00	1	Set Bypass Pump; Cleaned and Disinfected
66122	WQ0010495119	10200 HARWIN DR	Storm Sewer (not contained)	Yes	3210	Manhole	Grease Blockage	1/19/2026	12:26:00	1/19/2026	17:47:00	10	Cleared Main Line; Cleaned and Disinfected
66125	WQ0010495090	5114 LAURA KOPPE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/19/2026	15:00:00	1/19/2026	15:01:00	0	Cleaned and Disinfected; Cleared City Clean Out
66128	WQ0010495116	3122 ASHFORD ARBOR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	1/19/2026	16:45:00	1/19/2026	16:46:00	0	Cleaned and Disinfected; Cleared City Clean Out
66131	WQ0010495090	3021 BAIN ST	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	471	Private Cleanout	Collection system structural failure	1/20/2026	9:28:00	1/20/2026	12:05:00	3	Set Bypass Pump; Cleaned and Disinfected
66134	WQ0010495030	2666 MARILEE LN	Storm Sewer (not contained)	Yes	2280	Private Cleanout	Grease Blockage	1/20/2026	9:47:00	1/20/2026	13:35:00	10	Cleared Main Line; Cleaned and Disinfected
66136	WQ0010495090	301 SYLVESTER RD	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	0	City Cleanout	Rags/Wipes	1/20/2026	11:16:00	1/20/2026	11:17:00	0	Cleaned and Disinfected; Cleared City Clean Out

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
66137	WQ0010495090	515 MELBOURNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/20/2026	11:43:00	1/20/2026	11:44:00	0	Cleaned and Disinfected; Cleared City Clean Out
66143	WQ0010495119	12109 TAMBOURINE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/20/2026	14:05:00	1/20/2026	14:06:00	0	Cleared City Clean Out; Cleaned and Disinfected
66147	WQ0010495090	407 5TH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural failure	1/20/2026	15:39:00	1/20/2026	15:40:00	0	Cleaned and Disinfected; Set Bypass Pump
66149	WQ0010495076	6000 SUNFOREST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	173	Manhole	Grease Blockage	1/20/2026	16:07:00	1/20/2026	19:00:00	1	Cleared Main Line; Cleaned and Disinfected
66150	WQ0010495119	11203 PENDER LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	1/20/2026	17:00:00	1/20/2026	17:01:00	0	Cleared Main Line
66158	WQ0010495076	3527 MANSFIELD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/21/2026	11:39:00	1/21/2026	11:40:00	0	Cleared City Clean Out; Cleaned and Disinfected
66162	WQ0010495090	5510 CROOMS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/21/2026	13:00:00	1/21/2026	13:01:00	0	Cleared Service Lateral; Cleaned and Disinfected
66167	WQ0010495090	4423 WEAVER RD	Storm Sewer (not contained)	Yes	0	City Cleanout	Grease Blockage	1/21/2026	15:15:00	1/21/2026	15:16:00	0	Cleaned and Disinfected; Cleared City Clean Out
66169	WQ0010495037	3398 FONDREN RD	Storm Sewer (not contained)	Yes	508	Manhole	Grease Blockage	1/21/2026	15:46:00	1/21/2026	20:00:00	2	Cleaned and Disinfected; Cleared Main Line
66170	WQ0010495090	1207 PRAIRIE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/21/2026	18:01:00	1/21/2026	18:02:00	0	Cleared City Clean Out; Cleaned and Disinfected
66172	WQ0010495090	2019 CRAWFORD ST	Storm Sewer (not contained)	Yes	95	Service Lateral	Rags/Wipes	1/22/2026	11:39:00	1/22/2026	13:14:00	1	Cleared Main Line; Cleaned and Disinfected
66179	WQ0010495002	7710 ADRIAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/22/2026	15:02:00	1/22/2026	15:03:00	0	Cleared Main Line; Cleaned and Disinfected
66182	WQ0010495090	9016 LONESTAR RIVER LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/22/2026	14:30:00	1/22/2026	14:31:00	0	Cleared Main Line; Cleaned and Disinfected
66187	WQ0010495090	1043 MARCOLIN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/23/2026	9:41:00	1/23/2026	9:42:00	0	Cleaned and Disinfected; Cleared City Clean Out
66188	WQ0010495090	1119 HARRINGTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/23/2026	10:27:00	1/23/2026	10:28:00	0	Cleaned and Disinfected
66189	WQ0010495090	6505 VICTORIA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/23/2026	9:45:00	1/23/2026	9:46:00	0	Cleaned and Disinfected
66193	WQ0010495077	12706 COULSON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/23/2026	12:00:00	1/23/2026	12:01:00	0	Cleared City Clean Out; Cleaned and Disinfected
66196	WQ0010495119	11717 KIRKWOOD RD	Storm Sewer (not contained)	Yes	746	Manhole	Grease Blockage	1/23/2026	14:48:00	1/23/2026	21:01:00	2	Cleared Main Line; Cleaned and Disinfected
66197	WQ0010495090	6622 LAVENDER ST	Bayou/surface water/drainage ditch	Yes	0	Service Lateral	Collection system structural blockage	1/23/2026	15:07:00	1/23/2026	15:08:00	0	Cleared Private Line; Cleaned and Disinfected
66198	WQ0010495076	12238 HEMPSTEAD RD	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Grease Blockage	1/23/2026	15:44:00	1/23/2026	15:45:00	0	Cleared City Clean Out; Cleaned and Disinfected
66199	WQ0010495077	12703 EASTBROOK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/23/2026	15:41:00	1/23/2026	15:42:00	0	Cleared City Clean Out; Cleaned and Disinfected
66203	WQ0010495090	3412 GRAUSTARK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/23/2026	17:08:00	1/23/2026	17:09:00	0	Cleaned and Disinfected; Cleared City Clean Out
66205	WQ0010495002	4914 COSBY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/24/2026	9:18:00	1/24/2026	9:19:00	0	Cleaned and Disinfected
66211	WQ0010495037	4815 TONAWANDA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/25/2026	20:26:00	1/25/2026	20:27:00	0	Cleared Main Line; Cleaned and Disinfected
66212	WQ0010495037	4066 NENANA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/25/2026	15:04:00	1/25/2026	15:05:00	0	Cleaned and Disinfected
66213	WQ0010495009	4822 SCENIC DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/25/2026	15:05:00	1/25/2026	15:06:00	0	Set Bypass Pump; Cleaned and Disinfected
66214	WQ0010495037	4070 NENANA DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/25/2026	15:53:00	1/25/2026	15:54:00	0	Cleaned and Disinfected
66216	WQ0010495037	2720 BRIARHURST DR	Storm Sewer (not contained)	Yes	141	City Cleanout	Rags/Wipes	1/26/2026	12:19:00	1/26/2026	14:40:00	1	Cleared Service Lateral; Cleaned and Disinfected
66218	WQ0010495010	210 BOLDEN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/26/2026	12:37:00	1/26/2026	12:38:00	0	Cleared City Clean Out; Cleaned and Disinfected
66224	WQ0010495002	5939 BELNEATH ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/26/2026	15:18:00	1/26/2026	15:19:00	0	Cleared Main Line; Cleaned and Disinfected
66225	WQ0010495111	11238 STROUD DR	Storm Sewer (not contained)	Yes	22275	Manhole	Grease Blockage	1/26/2026	14:58:00	1/26/2026	17:35:00	142	Cleaned and Disinfected; Cleared Main Line



SSO ID	TPDES #	Address	Flow Location	Reached Waters of the US	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
66226	WQ0010495111	7303 AUTUMN GROVE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/26/2026	16:16:00	1/26/2026	16:17:00	0	Cleared City Clean Out; Cleaned and Disinfected
66227	WQ0010495110	7319 MACZALI DR	Storm Sewer (not contained)	Yes	2406	Manhole	Grease Blockage	1/26/2026	15:47:00	1/27/2026	11:50:00	2	Cleared Main Line; Cleaned and Disinfected
66231	WQ0010495003	1212 WILLARD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/27/2026	9:36:00	1/27/2026	9:37:00	0	Cleared Main Line; Cleaned and Disinfected
66238	WQ0010495139	10259 COTTAGE FIELD RD	Storm Sewer (not contained)	Yes	0	City Cleanout	Rags/Wipes	1/27/2026	10:59:00	1/27/2026	11:00:00	0	Cleared City Clean Out; Cleaned and Disinfected
66240	WQ0010495111	4503 KIRKWOOD RD	Storm Sewer (not contained)	Yes	778	Manhole	Grease Blockage	1/27/2026	10:41:00	1/27/2026	17:10:00	2	Cleared Main Line; Cleaned and Disinfected
66243	WQ0010495037	7702 NAIRN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1779	Private Cleanout	Grease Blockage	1/27/2026	10:52:00	1/28/2026	16:31:00	1	Cleared Main Line; Cleaned and Disinfected
66245	WQ0010495119	11518 CHARIOT DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	8320	Manhole	Collection system structural failure	1/27/2026	12:10:00	1/30/2026	9:30:00	2	Set Bypass Pump; Cleaned and Disinfected
66246	WQ0010495090	5615 DENMARK ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	501	Service Lateral	Grease Blockage	1/27/2026	12:04:00	1/27/2026	14:51:00	3	Cleaned and Disinfected; Cleared Main Line
66249	WQ0010495037	8205 FONDREN RD	Storm Sewer (not contained)	Yes	8355	Manhole	Grease Blockage	1/27/2026	11:57:00	1/28/2026	15:48:00	5	Cleared Main Line; Cleaned and Disinfected
66253	WQ0010495090	518 SPELL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/27/2026	13:28:00	1/27/2026	13:29:00	0	Cleaned and Disinfected
66259	WQ0010495111	11855 DASHWOOD DR	Storm Sewer (not contained)	Yes	0	City Cleanout	Grease Blockage	1/27/2026	15:13:00	1/27/2026	15:14:00	0	Cleaned and Disinfected; Cleared Main Line
66260	WQ0010495009	3419 ALMEDA GENOA RD	Storm Sewer (not contained)	Yes	5632	City Cleanout	Collection system structural failure	1/27/2026	16:02:00	1/28/2026	15:30:00	4	Cleaned and Disinfected
66263	WQ0010495111	11528 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	0	Private Cleanout	Collection system structural failure	1/27/2026	16:37:00	1/27/2026	16:38:00	0	Set Bypass Pump
66264	WQ0010495030	1119 WISTERWOOD DR	Storm Sewer (not contained)	Yes	11910	Service Lateral	Rags/Wipes	1/27/2026	16:17:00	1/28/2026	12:08:00	10	Cleaned and Disinfected; Cleared Main Line
66267	WQ0010495002	711 MEDINA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/28/2026	10:21:00	1/28/2026	10:22:00	0	Cleaned and Disinfected
66268	WQ0010495110	5003 RIDGE CREEK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/28/2026	10:25:00	1/28/2026	10:26:00	0	Cleaned and Disinfected; Set Bypass Pump
66271	WQ0010495110	8306 BLUE QUAIL DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2576	Manhole	Grease Blockage	1/28/2026	16:08:00	1/30/2026	11:04:00	1	Cleaned and Disinfected; Cleared Main Line
66274	WQ0010495002	6350 TELEPHONE RD	Storm Sewer (not contained)	Yes	2718	Manhole	Grease Blockage	1/28/2026	13:46:00	1/29/2026	12:25:00	2	Cleared Main Line; Cleaned and Disinfected
66280	WQ0010495003	3747 PURDUE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Service Lateral	Collection system structural failure	1/29/2026	10:06:00	1/29/2026	10:07:00	0	Cleaned and Disinfected
66284	WQ0010495111	13207 CAPE PROVINCE DR	Storm Sewer (not contained)	Yes	506	Manhole	Grease Blockage	1/29/2026	10:37:00	1/29/2026	14:50:00	2	Cleared Main Line; Cleaned and Disinfected
66292	WQ0010495002	4105 LAMAR ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/29/2026	16:30:00	1/29/2026	16:31:00	0	Cleaned and Disinfected; Cleared City Clean Out
66294	WQ0010495090	6403 HARDY RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/29/2026	18:48:00	1/29/2026	18:49:00	0	Cleaned and Disinfected
66297	WQ0010495003	3105 GRASSMERE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/30/2026	8:26:00	1/30/2026	8:27:00	0	Cleaned and Disinfected; Cleared Main Line
66298	WQ0010495090	9480 LONG POINT RD	Storm Sewer (not contained)	Yes	383	City Cleanout	Collection system structural failure	1/30/2026	8:57:00	1/30/2026	15:20:00	1	Set Bypass Pump; Cleaned and Disinfected
66303	WQ0010495090	5233 NETT ST	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	93	Service Lateral	Grease Blockage	1/30/2026	11:54:00	1/30/2026	15:00:00	0	Cleared Main Line; Cleaned and Disinfected
66307	WQ0010495003	3107 GRASSMERE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/30/2026	13:42:00	1/30/2026	13:43:00	0	Cleared Main Line; Cleaned and Disinfected
66310	WQ0010495119	9797 MEADOWGLEN LN	Storm Sewer (not contained)	Yes	2170	Manhole	Grease Blockage	1/30/2026	15:04:00	1/30/2026	17:36:00	14	Cleared Main Line; Cleaned and Disinfected
66315	WQ0010495003	3107 GRASSMERE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1155	Manhole	Collection system structural failure	1/31/2026	9:10:00	1/31/2026	15:35:00	3	Cleared Main Line; Cleaned and Disinfected
66316	WQ0010495090	3432 EASY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/31/2026	10:20:00	1/31/2026	10:21:00	0	Cleared City Clean Out; Cleaned and Disinfected
66318	WQ0010495002	2820 DALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/31/2026	10:50:00	1/31/2026	10:51:00	0	Cleared City Clean Out; Cleaned and Disinfected
66319	WQ0010495119	11455 BISSONNET ST	Storm Sewer (not contained)	Yes	752	Manhole	Grease Blockage	1/31/2026	11:28:00	1/31/2026	14:36:00	4	Cleaned and Disinfected; Cleared Main Line

Total Number of SSOs:	160
Number of Fish Kills Caused by SSOs:	0
Number of Notifications to the Public:	0
TWC § 7.251 Report Attached:	No

