



February 25, 2022

Associate Director, Water Enforcement  
U.S. Environmental Protection Agency  
Region VI  
1201 Elm Street, Suite 500  
Mail Code ECADW  
Dallas, Texas 75270-2102

Via USPS Certified Mail  
# 7021 1970 0000 7631 7902  
Via E-mail: [Smalley.bryant@epa.gov](mailto:Smalley.bryant@epa.gov)

Re: City of Houston Wastewater Consent Decree  
Monthly SSO Report  
DOJ No. 90-5-1-1-08687/1

Dear Mr. Smalley:

A copy of the monthly SSO summary report for January 2022 and SSO map are attached and is provided in compliance with Consent Decree requirements.

*I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering such information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.*

Sincerely,  
DocuSigned by:

A handwritten signature in cursive script that reads "Phillip Goodwin".  
0983519C2697428

Phillip Goodwin  
Regulatory Compliance Director  
Houston Public Works, City of Houston

Enc. January 2022 Monthly SSO Report; SSO Map for January 2022

cc via email: Nathaniel Douglas, DOJ ([Nathaniel.douglas@usdoj.gov](mailto:Nathaniel.douglas@usdoj.gov))  
James Zimny, EPA ([Zimny.james@epa.gov](mailto:Zimny.james@epa.gov))  
Alan Vaughn, EPA ([vaughn.alan@epa.gov](mailto:vaughn.alan@epa.gov))  
Phillip Ledbetter, Texas AG's Office ([phillip.ledbetter@oag.texas.gov](mailto:phillip.ledbetter@oag.texas.gov));  
James Sallans, TCEQ ([james.sallans@tceq.texas.gov](mailto:james.sallans@tceq.texas.gov))  
Kristen Schlemmer, BCWK ([kristen@bayoucitywaterkeeper.org](mailto:kristen@bayoucitywaterkeeper.org))

SSO ID	TPDES Permit #	Address	Flow Location	Reached Waters of the US and/or TX	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
13022	WQ0010495111	7303 AUTUMN GROVE DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/1/2022	10:41	1/1/2022	10:41	0	Cleaned and Disinfected;Cleared City Clean Out
13023	WQ0010495016	8407 SULTAN DR	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	1/1/2022	11:10	1/1/2022	11:10	0	Cleaned and Disinfected;Monitor Receiving Waterbody
13020	WQ0010495090	3802 DABNEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/1/2022	9:28	1/1/2022	9:28	0	Cleaned and Disinfected;Cleared Main Line
13026	WQ0010495037	5855 ETRICK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/1/2022	15:01	1/1/2022	15:01	0	Cleared Main Line;Cleaned and Disinfected
13032	WQ0010495003	1520 BAILEY ST	Storm Sewer (not contained)	Yes	176	Manhole	Grease Blockage	1/3/2022	10:34	1/3/2022	13:30	1	Cleared Main Line;Cleaned and Disinfected
13036	WQ0010495003	2001 WOODHEAD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1305	Manhole	Grease Blockage	1/3/2022	15:15	1/4/2022	13:00	1	Cleared Main Line;Cleaned and Disinfected
13031	WQ0010495090	4410 NINA LEE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural failure	1/3/2022	10:29	1/3/2022	10:29	0	Cleaned and Disinfected;Set Bypass Pump
13035	WQ0010495090	2450 ALDINE WESTFIELD RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/3/2022	14:02	1/3/2022	14:02	0	Cleaned and Disinfected;Cleared Main Line
13042	WQ0010495016	9226 TALTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/4/2022	11:30	1/4/2022	11:30	0	Cleared Main Line;Cleaned and Disinfected
13044	WQ0010495090	2345 MARGARET ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	1/4/2022	11:59	1/4/2022	11:59	0	Cleared Service Lateral;Cleaned and Disinfected
13050	WQ0010495090	513 VINCENT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/4/2022	15:59	1/4/2022	15:59	0	Cleaned and Disinfected;Cleared City Clean Out;Cleared Main Line
13048	WQ0010495002	5314 NEWKIRK LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	2880	Manhole	Grease Blockage	1/4/2022	12:51	1/6/2022	12:50	1	Cleared Main Line;Cleaned and Disinfected
13060	WQ0010495003	1520 BAILEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/5/2022	9:45	1/5/2022	9:45	0	Cleared Main Line;Cleaned and Disinfected
13067	WQ0010495090	1422 LAWRENCE ST	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	1/5/2022	14:09	1/5/2022	14:09	0	Cleared Main Line;Cleaned and Disinfected
13063	WQ0010495119	8565 W SAM HOUSTON PKWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	554	Manhole	Grease Blockage	1/5/2022	11:10	1/5/2022	15:30	2	Cleaned and Disinfected;Cleared Main Line
13083	WQ0010495119	8565 W SAM HOUSTON PKWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	780	Manhole	Grease Blockage	1/5/2022	11:10	1/5/2022	15:30	3	Cleared Main Line;Cleaned and Disinfected
13069	WQ0010495148	8602 VALLEY SONG DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/5/2022	15:42	1/5/2022	15:42	0	Cleared Main Line;Cleaned and Disinfected
13077	WQ0010495111	10004 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	6202	Force Main	Collection system structural failure	1/6/2022	15:51	1/8/2022	10:00	2	Contain All or Portion of Spill;Cleaned and Disinfected;Monitor Receiving Waterbody
13079	WQ0010495016	8407 SULTAN DR	Bayou/surface water/drainage ditch	Yes	0	Manhole	Grease Blockage	1/6/2022	17:11	1/6/2022	17:11	0	Cleared Main Line;Cleaned and Disinfected;Monitor Receiving Waterbody
13076	WQ0010495090	3802 DABNEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/6/2022	15:15	1/6/2022	15:15	0	Cleared Main Line;Cleaned and Disinfected
13071	WQ0010495002	711 LENOX ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural failure	1/6/2022	8:59	1/6/2022	8:59	0	Cleaned and Disinfected;Cleared Service Lateral
13084	WQ0010495003	3026 DAWSON LN	Bayou/surface water/drainage ditch	Yes	3138	Manhole	Grease Blockage	1/7/2022	8:24	1/7/2022	17:06	6	Cleared Main Line;Cleaned and Disinfected
13085	WQ0010495119	12023 BISSONNET ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	570	Manhole	Grease Blockage	1/7/2022	8:32	1/7/2022	11:42	3	Cleared Main Line;Cleaned and Disinfected
13090	WQ0010495090	4121 WIPPRECHT ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	1/7/2022	12:44	1/7/2022	12:44	0	Cleaned and Disinfected;Cleared Service Lateral
13092	WQ0010495002	1845 PASADENA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Roots	1/7/2022	13:17	1/7/2022	13:17	0	Cleaned and Disinfected;Cleared Service Lateral
13093	WQ0010495090	2823 COCHRAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Rags/Wipes	1/7/2022	13:46	1/7/2022	13:46	0	Cleaned and Disinfected;Cleared Service Lateral
13094	WQ0010495076	3401 BLALOCK RD	Storm Sewer (not contained)	Yes	436	Manhole	Grease Blockage	1/7/2022	14:55	1/7/2022	22:10	1	Cleared Main Line;Cleaned and Disinfected
13096	WQ0010495002	7832 GROVE RIDGE DR	Storm Sewer (not contained)	Yes	489	Manhole	Roots	1/7/2022	16:57	1/7/2022	19:40	3	Cleared Main Line;Cleaned and Disinfected



City of Houston - Houston Public Works  
 Monthly SSO Report  
 January 2022

SSO ID	TPDES Permit #	Address	Flow Location	Reached Waters of the US and/or TX	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
13104	WQ0010495090	3502 MELBOURNE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/8/2022	15:36	1/8/2022	15:36	0	Cleaned and Disinfected;Cleared Main Line
13108	WQ0010495009	12110 JUTLAND RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	1/9/2022	11:37	1/9/2022	11:37	0	Cleaned and Disinfected
13109	WQ0010495077	13339 EMPORIA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/9/2022	12:01	1/11/2022	17:52	0	Cleared Main Line;Cleaned and Disinfected
13114	WQ0010495119	7710 BARBERTON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	60	City Cleanout	Grease Blockage	1/9/2022	14:45	1/10/2022	11:50	0	Cleaned and Disinfected;Cleared Main Line
13115	WQ0010495152	16100 GALVESTON RD	Storm Sewer (not contained)	Yes	3350	Manhole	Grease Blockage	1/9/2022	17:06	1/9/2022	19:20	25	Cleared Main Line;Cleaned and Disinfected
13152	WQ0010495152	16100 GALVESTON RD	Storm Sewer (not contained)	Yes	3350	Manhole	Grease Blockage	1/9/2022	17:06	1/9/2022	19:20	25	Cleared Main Line;Cleaned and Disinfected
13118	WQ0010495111	10004 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	12000	Force Main	Collection system structural failure	1/10/2022	7:30	1/11/2022	21:20	5	Contain All or Portion of Spill;Cleaned and Disinfected;Returned Spill to Sanitary System;Set Bypass Pump
13120	WQ0010495076	5510 ROSSLYN RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/10/2022	11:24	1/10/2022	11:24	0	Cleared City Clean Out;Cleaned and Disinfected
13129	WQ0010495002	5935 SOUTHSEAS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/11/2022	10:26	1/11/2022	10:26	0	Cleared Main Line;Cleaned and Disinfected
13130	WQ0010495002	5970 DOOLITTLE BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/11/2022	10:30	1/11/2022	10:30	0	Cleared Main Line;Cleaned and Disinfected
13136	WQ0010495009	10513 MURR WAY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	1/11/2022	14:55	1/11/2022	14:55	0	Set Bypass Pump;Cleaned and Disinfected
13138	WQ0010495090	302 HAHLO ST	Storm Sewer (not contained)	Yes	0	Gravity Main	Rags/Wipes	1/11/2022	18:02	1/11/2022	18:02	0	Cleared Main Line;Cleaned and Disinfected
13142	WQ0010495016	10938 CHEEVES DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/12/2022	10:02	1/12/2022	10:02	0	Cleaned and Disinfected;Cleared Main Line
13145	WQ0010495090	10223 SILVERCREST ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Rags/Wipes	1/12/2022	10:40	1/12/2022	10:40	0	Cleared City Clean Out;Cleaned and Disinfected
13150	WQ0010495090	9211 SHOREHAM ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/12/2022	12:47	1/12/2022	12:47	0	Cleared Main Line;Cleaned and Disinfected
13158	WQ0010495119	8015 BEECHNUT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1648	Manhole	Rags/Wipes	1/12/2022	15:46	1/13/2022	19:14	1	Cleared Main Line;Cleaned and Disinfected
13160	WQ0010495111	10004 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	1200	Force Main	Collection system structural failure	1/12/2022	17:14	1/12/2022	18:22	18	Cleaned and Disinfected;Contain All or Portion of Spill;Set Bypass Pump;Returned Spill to Sanitary System
13166	WQ0010495119	3774 TANGLEWILDE ST	Storm Sewer (not contained)	Yes	330	Manhole	Grease Blockage	1/13/2022	10:18	1/13/2022	13:03	2	Cleared Main Line;Cleaned and Disinfected
13167	WQ0010495111	9510 BEECHNUT ST	Storm Sewer (not contained)	Yes	4552	Manhole	Collection system structural failure	1/13/2022	10:27	1/13/2022	18:54	9	Set Bypass Pump;Cleaned and Disinfected;Post Warning Signs
13170	WQ0010495109	2150 BENTWORTH DR	Storm Sewer (not contained)	Yes	466	City Cleanout	Rags/Wipes	1/13/2022	11:47	1/13/2022	15:40	2	Cleared City Clean Out;Cleaned and Disinfected
13172	WQ0010495030	302 GREENPARK DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/13/2022	14:00	1/13/2022	14:00	0	Cleared City Clean Out;Cleaned and Disinfected
13173	WQ0010495090	6805 NORDLING RD	Storm Sewer (not contained)	Yes	0	City Cleanout	Collection system structural blockage	1/13/2022	14:34	1/13/2022	14:34	0	Cleaned and Disinfected;Cleared Service Lateral
13183	WQ0010495010	8675 CLINTON DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Sample Well	Collection system structural failure	1/14/2022	12:13	1/14/2022	12:13	0	Cleaned and Disinfected
13185	WQ0010495037	5551 ROYALTON ST	Storm Sewer (not contained)	Yes	480	Manhole	Collection system structural blockage	1/14/2022	13:26	1/14/2022	16:05	3	Cleaned and Disinfected;Set Bypass Pump
13188	WQ0010495090	3608 FARMER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/14/2022	18:20	1/14/2022	18:20	0	Cleared Service Lateral;Cleaned and Disinfected

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.

SSO ID	TPDES Permit #	Address	Flow Location	Reached Waters of the US and/or TX	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
13198	WQ0010495002	6926 S LOOP FWY	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	42	Manhole	Grease Blockage	1/16/2022	9:45	1/16/2022	12:00	0	Cleared Main Line;Cleaned and Disinfected
13204	WQ0010495076	5910 PAR FOUR DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/17/2022	9:30	1/17/2022	9:30	0	Cleared Main Line;Cleaned and Disinfected
13206	WQ0010495003	15111 BATHURST DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	326	Manhole	Grease Blockage	1/17/2022	9:21	1/17/2022	16:48	1	Cleaned and Disinfected;Cleared Main Line
13219	WQ0010495002	6030 RIDGEWAY DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/18/2022	10:34	1/18/2022	10:34	0	Cleared City Clean Out;Cleaned and Disinfected
13229	WQ0010495002	3801 TELEPHONE RD	Storm Sewer (not contained)	Yes	95	Manhole	Grease Blockage	1/18/2022	14:05	1/18/2022	15:40	1	Cleaned and Disinfected;Cleared Main Line
13230	WQ0010495003	2511 WILLOWICK RD	Storm Sewer (not contained)	Yes	752	Manhole	Grease Blockage	1/18/2022	14:22	1/18/2022	17:30	4	Cleared Main Line;Cleaned and Disinfected
13232	WQ0010495002	1545 MUNGER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/18/2022	16:37	1/18/2022	16:37	0	Cleaned and Disinfected;Cleared City Clean Out
13233	WQ0010495079	9523 GULF BRIDGE ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/18/2022	17:25	1/18/2022	17:25	0	Cleaned and Disinfected;Cleared City Clean Out
13234	WQ0010495090	6805 NORDLING RD	Bayou/surface water/drainage ditch	Yes	2668	City Cleanout	Collection system structural blockage	1/18/2022	17:46	1/19/2022	16:00	2	Cleaned and Disinfected;Set Bypass Pump
13238	WQ0010495109	13910 LOCKE LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/19/2022	10:40	1/19/2022	10:40	0	Cleaned and Disinfected;Cleared Main Line
13240	WQ0010495090	301 N DRENNAN ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/19/2022	11:51	1/19/2022	11:51	0	Cleared Main Line;Cleaned and Disinfected
13243	WQ0010495090	6705 NAVIGATION BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/19/2022	13:04	1/19/2022	13:04	0	Cleared Service Lateral;Cleaned and Disinfected
13244	WQ0010495002	3505 BLODGETT ST	Storm Sewer (not contained)	Yes	160	Manhole	Grease Blockage	1/19/2022	12:48	1/19/2022	13:41	3	Cleaned and Disinfected;Cleared Main Line
13248	WQ0010495009	5305 WENDA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	1/19/2022	15:01	1/19/2022	15:01	0	Cleaned and Disinfected;Cleared Service Lateral
13250	WQ0010495002	6606 KELLER ST	Storm Sewer (not contained)	Yes	1260	Manhole	Collection system temporary blockage	1/19/2022	13:35	1/20/2022	10:35	1	Cleaned and Disinfected
13253	WQ0010495003	14506 PLAYER ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/19/2022	17:42	1/19/2022	17:42	0	Cleaned and Disinfected;Cleared Main Line
13254	WQ0010495076	8630 KEMPWOOD DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/19/2022	19:41	1/19/2022	19:41	0	Cleaned and Disinfected;Cleared Main Line
13255	WQ0010495002	3852 TELEPHONE RD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/20/2022	8:18	1/20/2022	8:18	0	Cleaned and Disinfected;Cleared Main Line
13263	WQ0010495002	926 RUELL ST	Storm Sewer (not contained)	Yes	1440	Manhole	Grease Blockage	1/20/2022	11:10	1/21/2022	11:10	1	Cleaned and Disinfected;Cleared Main Line
13265	WQ0010495076	3102 TILSON LN	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/20/2022	13:05	1/20/2022	13:05	0	Cleared Service Lateral;Cleaned and Disinfected
13270	WQ0010495009	4700 WENDA ST	Storm Sewer (not contained)	Yes	336	Manhole	Grease Blockage	1/20/2022	17:20	1/20/2022	19:12	3	Cleared Main Line;Cleaned and Disinfected
13271	WQ0010495009	4700 WENDA ST	Storm Sewer (not contained)	Yes	336	Manhole	Grease Blockage	1/20/2022	17:20	1/20/2022	19:12	3	Cleared Main Line;Cleaned and Disinfected
13274	WQ0010495037	7902 CANDLE LN	Storm Sewer (not contained)	Yes	169	Manhole	Grease Blockage	1/21/2022	12:15	1/21/2022	15:04	1	Cleared Main Line;Cleaned and Disinfected
13277	WQ0010495003	2108 BANKS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Gravity Main	Collection system structural blockage	1/21/2022	14:53	1/21/2022	14:53	0	Cleaned and Disinfected;Contain All or Portion of Spill;Returned Spill to Sanitary System
13279	WQ0010495090	406 HUTCHESON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Collection system structural blockage	1/21/2022	15:15	1/21/2022	15:15	0	Cleared Main Line;Cleaned and Disinfected;Set Bypass Pump
13280	WQ0010495090	1910 TIDWELL	Storm Sewer (not contained)	Yes	3672	Manhole	Grease Blockage	1/21/2022	15:21	1/22/2022	11:45	3	Cleared Main Line;Cleaned and Disinfected
13282	WQ0010495002	7531 GLENHEATH ST	Storm Sewer (not contained)	Yes	125	Manhole	Grease Blockage	1/21/2022	15:25	1/21/2022	17:30	1	Cleared Main Line;Cleaned and Disinfected

SSO ID	TPDES Permit #	Address	Flow Location	Reached Waters of the US and/or TX	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
13283	WQ0010495003	5334 RIPPLEBROOK DR	Storm Sewer (not contained)	Yes	1205	Manhole	Grease Blockage	1/21/2022	15:40	1/22/2022	11:45	1	Cleared Main Line;Cleaned and Disinfected
13287	WQ0010495139	5002 RAINDROP HOLLOW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	987	Manhole	Grease Blockage	1/22/2022	9:31	1/22/2022	15:00	3	Cleared Main Line;Cleaned and Disinfected
13290	WQ0010495119	9012 BEECHNUT ST	Storm Sewer (not contained)	Yes	402	Manhole	Grease Blockage	1/22/2022	14:16	1/22/2022	17:30	2	Cleaned and Disinfected;Cleared Main Line
13291	WQ0010495111	13003 GREENWAY CHASE CT	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	1885	Manhole	Grease Blockage	1/23/2022	8:23	1/24/2022	15:48	1	Cleared Main Line;Cleaned and Disinfected
13293	WQ0010495003	1960 INDIANA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	526	Manhole	Grease Blockage	1/23/2022	10:06	1/23/2022	14:29	2	Cleared Main Line;Cleaned and Disinfected
13300	WQ0010495030	10006 WESTVIEW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/24/2022	9:04	1/24/2022	9:04	0	Cleared City Clean Out;Cleaned and Disinfected
13301	WQ0010495037	5551 ROYALTON ST	Storm Sewer (not contained)	Yes	127	Manhole	Collection system structural blockage	1/24/2022	9:47	1/24/2022	11:59	1	Cleaned and Disinfected
13307	WQ0010495002	5806 SOUTHSEAS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/24/2022	12:59	1/24/2022	12:59	0	Cleared Service Lateral;Cleaned and Disinfected
13322	WQ0010495023	7969 BLUE ST	Bayou/surface water/drainage ditch	Yes	0	City Cleanout	Collection system structural blockage	1/25/2022	10:47	1/25/2022	10:47	0	Cleared Service Lateral;Cleaned and Disinfected
13324	WQ0010495037	6100 BELLAIRE BLVD	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	1/25/2022	10:52	1/25/2022	10:52	0	Cleared Main Line;Cleaned and Disinfected
13329	WQ0010495002	7030 CAYTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Collection system structural blockage	1/25/2022	16:35	1/25/2022	16:35	0	Cleaned and Disinfected
13331	WQ0010495090	955 W 23RD ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/26/2022	10:30	1/26/2022	10:30	0	Cleared Main Line;Cleaned and Disinfected
13333	WQ0010495037	9410 BOB WHITE DR	Storm Sewer (not contained)	Yes	1078	Manhole	Grease Blockage	1/26/2022	9:55	1/26/2022	18:54	2	Cleared Main Line;Cleaned and Disinfected
13336	WQ0010495090	5850 KIAM ST	Bayou/surface water/drainage ditch	Yes	392	Manhole	Grease Blockage	1/26/2022	14:32	1/26/2022	21:03	1	Cleared Main Line;Cleaned and Disinfected
13338	WQ0010495003	4106 WORRELL DR	Within 5 ft. of Bayou/Surface Water/Drainage Ditch	Yes	424	Manhole	Grease Blockage	1/26/2022	15:58	1/26/2022	19:30	2	Cleared Main Line;Cleaned and Disinfected
13339	WQ0010495002	927 MAROBY ST	Storm Sewer (not contained)	Yes	1735	Manhole	Grease Blockage	1/26/2022	16:04	1/27/2022	11:21	1	Cleared Main Line;Cleaned and Disinfected
13340	WQ0010495030	10030 LAZY OAKS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Rags/Wipes	1/27/2022	9:29	1/27/2022	9:29	0	Cleared City Clean Out;Cleaned and Disinfected
13341	WQ0010495090	1003 KELLEY ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Private Cleanout	Grease Blockage	1/27/2022	9:32	1/27/2022	9:32	0	Cleared Service Lateral;Cleaned and Disinfected;Cleared Main Line
13343	WQ0010495090	2103 DAVIS ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/27/2022	10:08	1/27/2022	10:08	0	Cleared Service Lateral;Cleaned and Disinfected
13354	WQ0010495090	617 WARNER ST	Bayou/surface water/drainage ditch	Yes	255	Manhole	Grease Blockage	1/28/2022	10:23	1/28/2022	10:23	0	Cleaned and Disinfected;Cleared Main Line
13358	WQ0010495030	10000 HAMMERLY BLVD	Storm Sewer (not contained)	Yes	104	Manhole	Grease Blockage	1/28/2022	11:58	1/28/2022	11:58	0	Cleared Main Line;Cleaned and Disinfected
13364	WQ0010495037	8030 W AIRPORT BLVD	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Rags/Wipes	1/28/2022	17:34	1/28/2022	17:34	0	Cleared Main Line;Cleaned and Disinfected
13381	WQ0010495037	7054 HENDON LN	Storm Sewer (not contained)	Yes	4185	Manhole	Grease Blockage	1/29/2022	15:35	1/29/2022	15:35	0	Cleaned and Disinfected;Cleared Main Line
13390	WQ0010495002	6815 CRESTMONT ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	Manhole	Grease Blockage	1/30/2022	10:56	1/30/2022	10:56	0	Cleared Main Line;Cleaned and Disinfected
13393	WQ0010495119	8300 SANDS POINT DR	Storm Sewer (not contained)	Yes	1025	Manhole	Grease Blockage	1/30/2022	12:53	1/30/2022	12:53	0	Cleared Main Line;Cleaned and Disinfected
13397	WQ0010495030	10004 WESTVIEW DR	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	92	City Cleanout	Rags/Wipes	1/30/2022	14:11	1/30/2022	14:11	0	Cleared City Clean Out;Cleaned and Disinfected
13400	WQ0010495090	222 HOHLDALE ST	Storm Sewer (not contained)	Yes	0	Manhole	Grease Blockage	1/30/2022	16:13	1/30/2022	16:13	0	Cleared Main Line;Cleaned and Disinfected
13405	WQ0010495090	701 LINK RD	Bayou/surface water/drainage ditch	Yes	0	Private Cleanout	Collection system structural blockage	1/31/2022	8:57	1/31/2022	8:57	0	Cleaned and Disinfected




City of Houston - Houston Public Works  
 Monthly SSO Report  
 January 2022

SSO ID	TPDES Permit #	Address	Flow Location	Reached Waters of the US and/or TX	Est. Volume (Gallons)	Structure Type	Excursion Cause	Start Date	Start Time	End Date	End Time	Average Flow (GPM)	Corrective Action
13406	WQ0010495002	2201 PRESTON ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Collection system structural blockage	1/31/2022	9:27	1/31/2022	9:27	0	Cleaned and Disinfected;Cleared Service Lateral
13411	WQ0010495009	13202 LEA ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/31/2022	10:32	1/31/2022	10:32	0	Cleaned and Disinfected;Cleared City Clean Out
13416	WQ0010495090	995 JUNELL ST	Contained On Site, not within 5 ft. of Bayou/Surface Water/Drainage Ditch	No	0	City Cleanout	Grease Blockage	1/31/2022	14:48	1/31/2022	14:48	0	Cleaned and Disinfected;Cleared Service Lateral
13418	WQ0010495122	6426 SPRINGHAVEN DR	Bayou/surface water/drainage ditch	Yes	5622	Manhole	Grease Blockage	1/31/2022	15:23	1/31/2022	15:23	0	Cleaned and Disinfected;Cleared Main Line

Total Number of SSOs:	112
Number of Fish Kills Caused	1
Number of Notifications to TWC § 7.251 Report	0
	No

Additional Comments: Please note that where estimated volume and average flow are reported as "0", evidence of an SSO was observed but no active overflow was occurring. Consequently, flow rate and total volume loss could not be calculated.



**Legend**

- SSO location
- XXXXX SSO ID

# SSO Map for January 2022

DISCLAIMER: The following data sets were generated by and for the Houston Public Works Department. The asset information within this map are continually being updated, refined and are being provided to your organization for official use only and remains the property of the Houston Public Works Department. Providing this document to you does not constitute a release under the Freedom of Information Act (5 U.S.C. [section] 552), and due to the sensitivity of the information, this document must be appropriately safeguarded. PLEASE NOTE that these data sets are NOT intended to be used as an authoritative public record for any geographic location or as a legal document and have no legal force or effect. Users are responsible for checking the accuracy, completeness, currency and/or suitability of these datasets themselves. The Department makes no representation, guarantee or warranty as to the accuracy, completeness, currency, or suitability of these datasets, which are provided "AS IS"

